Module 1: Introduction

Water Resources Sustainability Conservation of Mass Principle (Handout): (See in course website: STUDY ASSIGNMENT/Handouts/Module 1

CWR 3540: Water Resources Engineering FIU Department of Civil & Environmental Engineering Professor Fuentes

HYDROSYSTEMS ↓		
Wate Needs	r Resources: and Impacts ↓	
Users ↓		
\checkmark	↓	
Supply: consumption (controlled Q)	Stormwater: surface runoff (variable Q)	
- Water Supply	- Non-urban	
- Wastewater	- Urban	
\checkmark	1	
Engineered Systems (e.g., pipelines, canals, storage, dams, etc.)	Drainage Areas (e.g., as a single dwelling property, parks, highways, airports, county, hydrologic drainage areas or watersheds etc.)	







Figure 1.1.1a McGraw Hill



Figure 1.5.1 © John Wiley & Sons, Inc. All rights reserved.



Figure 1.5.2 © John Wiley & Sons, Inc. All rights reserved.

Municipal Water Supply Systems

Figure 1.4 Layout of typical water supply systems.





Florida H-Idalia: Flooding & Control

(Landed as hurricane cat 3 on August 30 in the Big Bend of Florida): Control options: structural <u>and</u> non-structural control



OZELLO, FLORIDA BEFORE & AFTER IDALIA









Hurricane Francine Cat 2 (Landed Terrebonne Parish, LA, 4:00PM)







SUSTAINABILITY

- "Sustainable Development" to ensure that it meets the needs of the present without compromising the ability of future generations to meet their own needs (World Commission on Environment and Development, 1987)
- Initiated by the *Bruntland Commission* (General Assembly of the United Nations in 1984).







Figure 1.4.1 Images courtesy of NASA GSFC Scientific Visualization Studio and Landsat-7 Project

Module 1: Introduction Water Demand versus Supply

CWR 3540: Water Resources Engineering FIU Department of Civil & Environmental Engineering Professor Fuentes

Florida Water Supplies: Examples











Issues

- Development of water resources
 - Needs of users (or demand) <u>versus</u> supply(ies)?
 - Project Purposes:
 - Use:
 - water supply from surface and/or groundwater to meet user needs
 - Control:
 - ensuring recharge of groundwater and
 - managing precipitation-driven flood control)
- Questions
 - How much water is needed? How can it be reduced?
 - How much water is available? Is it impacted by droughts? And
 - How can the needs be met by supply(ies)?
 - How should the used-up water be safely "disposed" of? Re-used?
 - How to control flooding in cities after "extreme" storms

Issues (Cont.)

- Types of water supplies
 - Surface waters (also important path of recharge from precipitation):
 - streams,
 - rivers,
 - lakes,
 - ocean, etc.)
 - Groundwater:
 - unconfined and confined aquifers
 - with shallow and deep wells

Issues (Cont.)

- Assessment of demand versus supplies
 - Withdrawal (off-site import, e.g., out of stream)
 - Non-withdrawal (use on site, e.g., navigation)
 - Consumptive use (supply not longer available, e.g., water incorporated in crops)
- Municipal requirements (See concept in Fig. 1)

 Requirement (i.e., volumetric flow rate, L³/t))
 (Population at end of design period) x per capita use

Example: Water Use in City (Population = 150,000)





USA Sectors: Water Users

(Example 2005) https://water.usgs.gov/watuse/

- <u>Public supply</u> (12%)个 from 2005 to 2010
- <u>Domestic</u> (1%)
- <u>Irrigation</u> (33%) 个
- <u>Thermoelectric power</u> (49%)
- Industrial (4%)
- <u>Mining</u> (1%)
- <u>Livestock</u> (1%)
- <u>Aquaculture</u> (3%) 个

Population Forecasting

(Trend analysis)

- Short-term estimates (i.e., 1-10 years) (Fig. 1.2)
 - Graphical extension method
 - Arithmetic growth method (Eqs. 1.2-1.3 & Ex. 1.1)
 - Geometric growth method (Eqs. 1.4, 1.5 & Exs. 1.2, 1.4)
 - Declining growth rate method (Eqs. 1.6, 1..7 & Ex. 1.3)
- Long-term estimates (i.e., 10-50 years)
 - Graphic comparison method (Fig. 1.3)
 - Mathematical logistic curve method (Eq. 1.8-1.11, Ex. 1.5)
 - Ratio and correlation methods (Eqs. 1.12,1.13)
 - Components methods (based on birth, death and migration rates, Eq. 1.14)

Population Forecasting

Short-Term Estimates: Growth Methods



Population Forecasting

Long-Term Estimates: Growth Methods

Figure 1.3 Graphical projection by comparison.



Municipal Water Supply Systems

Figure 1.4 Layout of typical water supply systems.



Water Usage and Municipal Water Supply Infrastructure (Ex. 1.6)

Structure	Design Period ^a (years)	Required Capacity
1. Source of supply		
a. River	Indefinite	Maximum daily (requirements)
b. Well field	10–25	Maximum daily
c. Reservoir	25–50	Average annual demand
2. Conveyance		
a. Intake conduit	25-50	Maximum daily
b. Conduit to treatment plant	25–50	Maximum daily
3. Pumps		
a. Low-lift	10	Maximum daily plus one reserve unit
b. High-lift	10	Maximum hourly plus one reserve unit
4. Treatment plant	10–15	Maximum daily
5. Service reservoir	20–25	Working storage (storage capacity computation, Sect. 13.10) plus fire demand for a specified duration (Table 1.2) plus emergency storage
6. Distribution		
a. Supply pipe or conduit	25–50	Greater of (1) maximum daily plus fire
b. Distribution grid	Full development	demand of a day or (2) maximum hourly requirement

Table 1.1 Design Periods and Capacity Criteria for Constituent Structures

^a "Design period" does not necessarily indicate the life of the structure. A design period takes into account other factors, such as subsequent ease of extension, rate of population growth and shifts in community, and industrial/commercial developments.

Variations in Usage

- Average daily
- Variability in time
 - Hour
 - Week
 - Month
 - Season
 - year(s)
 - etc.
- Variability in space
 - hour,
 - week days,
 - seasons
 - etc.





Fire Demands for Municipal Use

- Estimation Methods
 - International Fire Code
 - National Fire Protection Association (NFPA)
 - Others
- Types of Construction
 - I through V (demand decreases from I to V)
 - A and B (i.e., A has higher fire resistance rating)
 - Floor area (see definition, p. 16)
- Requirements and Duration (Table 1.2 and Ex. 1.7)

Industrial Requirements

(1.10, p. 19)

Processes such as material processing, fabricating, incorporating in product, diluting, washing, transporting, cooling, etc.

Table 1.3Requirements of Major Industries

Industry	Average Water Use
Thermoelectric power	19 gal/kWh or 600 gpcd
Steel	62,000 gal/ton
Paper	39,000 gal/ton
Organic chemicals	55,000 gal/ton
Woolens	140,000 gal/ton
Coke (coal byproduct)	3,600 gal/ton
Petroleum refining	1850 gal/barrel
Plastic	24,000 gal/ton
Cement	36,500 gal/ton

Other Demands

- Irrigation (1.12, p. 22)
 - Consumptive Use of Crops
 - Effective Rainfall
 - Farm Losses
- Conveyance and Waste (1.16, p. 25)
- Hydropower (1.18, p. 30)
- Navigation (1.19, p. 33)

Hydroelectric Power Generation (Example)



Any Questions? See Syllabus for Official Assistance Hours